

Client:

Project: Pine Valley Central School

Service Request:R1705200

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R1705200-001	Elem. Kitchen Sink	6/6/2017	0627
R1705200-002	Elementary Faculty Rm	6/6/2017	0630
R1705200-003	Elem Library Drinking Ftn	6/6/2017	0634
R1705200-004	Elem Lobby Drinking Ftn	6/6/2017	0638
R1705200-005	Elem Nurse Sink	6/6/2017	0640
R1705200-006	Drinking Fountain Old Gym	6/6/2017	0640
R1705200-007	Main Office Conference Rm	6/6/2017	0640
R1705200-008	Rm 101 Drinking Ftn.	6/6/2017	0640
R1705200-009	Home EC Rm	6/6/2017	0640
R1705200-010	Pool Drinking Ftn.	6/6/2017	0640

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Elem. Kitchen Sink
Lab Code: R1705200-001

Service Request: R1705200
Date Collected: 06/06/17 06:27
Date Received: 06/07/17 19:00
Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	561	ug/L	10	10	06/13/17 12:46	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 17:21	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Elementary Faculty Rm
Lab Code: R1705200-002

Service Request: R1705200
Date Collected: 06/06/17 06:30
Date Received: 06/07/17 19:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Copper, Total	200.8	655	ug/L	10	10	06/13/17 12:50	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 17:34	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Elem Library Drinking Ftn
Lab Code: R1705200-003

Service Request: R1705200
Date Collected: 06/06/17 06:34
Date Received: 06/07/17 19:00
Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	334	ug/L	10	10	06/13/17 12:54	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 17:38	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Elem Lobby Drinking Ftn
Lab Code: R1705200-004

Service Request: R1705200
Date Collected: 06/06/17 06:38
Date Received: 06/07/17 19:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Copper, Total	200.8	541	ug/L	10	10	06/13/17 12:57	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 17:42	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Elem Nurse Sink
Lab Code: R1705200-005

Service Request: R1705200
Date Collected: 06/06/17 06:40
Date Received: 06/07/17 19:00

Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	625	ug/L	10	10	06/13/17 13:01	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/13/17 17:47	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Drinking Fountain Old Gym
Lab Code: R1705200-006

Service Request: R1705200
Date Collected: 06/06/17 06:40
Date Received: 06/07/17 19:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Copper, Total	200.8	908	ug/L	10	10	06/13/17 13:05	
Lead, Total	200.8	1.7	ug/L	1.0	1	06/12/17 17:51	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Main Office Conference Rm
Lab Code: R1705200-007

Service Request: R1705200
Date Collected: 06/06/17 06:40
Date Received: 06/07/17 19:00
Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	801	ug/L	10	10	06/13/17 13:09	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 18:03	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Rm 101 Drinking Ftn.
Lab Code: R1705200-008

Service Request: R1705200
Date Collected: 06/06/17 06:40
Date Received: 06/07/17 19:00

Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	507	ug/L	10	10	06/13/17 13:20	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 18:07	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Home EC Rm
Lab Code: R1705200-009

Service Request: R1705200
Date Collected: 06/06/17 06:40
Date Received: 06/07/17 19:00

Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	577	ug/L	10	10	06/13/17 13:24	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 18:11	

Analytical Report

Client:
Project: Pine Valley Central School
Sample Matrix: Drinking Water
Sample Name: Pool Drinking Ftn.
Lab Code: R1705200-010

Service Request: R1705200
Date Collected: 06/06/17 06:40
Date Received: 06/07/17 19:00
Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Copper, Total	200.8	472	ug/L	10	10	06/13/17 13:27	
Lead, Total	200.8	1.0 U	ug/L	1.0	1	06/12/17 18:16	